



# Ferring Funtime Community Pre-school

---

## **FIRE SAFETY AND EMERGENCY EVACUATION POLICY & PROCEDURE NO. 31**

### **Policy statement**

We ensure the highest possible standard of fire precautions are in place. The person in charge and our staff are familiar with the current legal requirements. Where necessary we seek the advice of a competent person, such as our Fire Officer or Fire Safety Consultant. A Fire Safety Log Book is used to record the findings of risk assessment, any actions taken or incidents that have occurred and our fire drills. We ensure our policy is in line with the procedures specific to our building, making reasonable adjustments as required.

### **Procedures**

#### *Fire safety risk assessment*

- The basis of fire safety is risk assessment, carried out by a 'competent person'.
- The manager has received training in fire safety sufficient to be competent to carry out the risk assessment; this will be written where there are more than five staff and will follow the Government Guidance Fire Safety Risk Assessment - Educational Premises (HMG 2006).
  - ~ Our fire safety risk assessment focuses on the following for each area of the setting:
  - ~ Electrical plugs, wires and sockets.
  - ~ Electrical items.
  - ~ Gas boilers.
  - ~ Cookers.
  - ~ Matches.
  - ~ Flammable materials – including furniture, furnishings, paper etc.
  - ~ Flammable chemicals.
  - ~ Means of escape.
  - ~ Anything else identified.
- Where we rent premises, we will ensure that we have a copy of the fire safety risk assessment that applies to the building and that we contribute to regular reviews.

### *Fire safety precautions taken*

- We ensure that fire doors are clearly marked, never obstructed and easily opened from the inside.
- We ensure that smoke detectors/alarms and firefighting appliances conform to BS EN standards, are fitted in appropriate high-risk areas of the building and are checked as specified by the manufacturer.
- We have all electrical equipment checked annually by a qualified electrician. Any faulty electrical equipment is taken out of use and either repaired or replaced.
- Our emergency evacuation procedures are approved by the Fire Safety Officer and are:
  - ~ clearly displayed in the premises;
  - ~ explained to new members of staff, volunteers and parents; and
  - ~ practised regularly, at least once every six weeks.
- Records are kept of fire drills and of the servicing of fire safety equipment.

### *Emergency evacuation procedure*

- Whistle is blown by adult who find the danger or has taken the message from the school. Ie Telephone or doorbell sound on the outer door.
- Phone 999 if safe to do so.
- All practitioners take the children within their area to the nearest safe exit (main door, door into veranda and the door leading to the outside play area).
- The supervisor should collect the rope, register, emergency records, check the building and then leave by the nearest safe exit.
- All adults, children and visitors should meet on the school field, just before the number 2 on the fence post.
- Emergency Services should be called if they have not been already.
- The children are then asked to hold onto the rope and the register is taken and the children counted.
- Should the school need to evacuate we would go to St Andrews Church Hall.
- Extinguishers are available for use if appropriate

### *Fire drills*

We hold fire drills termly and record the following information about each fire drill in the Fire Safety Log Book:

- The date and time of the drill.
- Number of adults and children involved.
- How long it took to evacuate.
- Whether there were any problems that delayed evacuation.
- Any further action taken to improve the drill procedure.

**Legal framework**

- Regulatory Reform (Fire Safety) Order 2005

**Further guidance**

Fire Safety Risk Assessment - Educational Premises (HMG 2006)

**This policy was updated and adopted on.....**10<sup>th</sup> October 2019.....

**To be reviewed by .....**October 2020.....

**Signed on behalf of the pre-school**

8Thwades

..... **Chair**

S.Cooper.

..... **Manager**